



**Office of Capital Planning
and Project Management**

DIVISION 21

**FIRE
SUPPRESSION**

This Article on Codes, Regulation and Standards shall apply
to all Divisions of the Building Standards

Table of Contents

SECTION 21 11 00 – FACILITY FIRE-SUPPRESSION WATER-SERVICE PIPING.....2

**SECTION 21 11 00 – FACILITY FIRE-SUPPRESSION
WATER-SERVICE PIPING**

- All pipes going through walls or floors shall go through sleeves, and the openings in the sleeves shall be fire caulked.
- The standard pipe for Fire Suppression applications shall be Schedule 40.
- Refer to Division 28, [Section 28 30 00](#), Electronic Detection and Alarm.

END OF SECTION 21 11 00

This section of the Building Standards establishes minimum requirements only.
It should not be used as a complete specification